



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22862128, Fax No.080-22862126,
E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in
No: GM (Q,S&S)/DGM-3/BC-11/18-19 / *CYS-112*
Encl:

O/o GM(QS&S)
No:12, J.P Avenue, Curve road,
Tasker Town, Bangalore-51
Date: *09-10-2018*

OFFICIAL MEMORANDUM

Sub :	Vendor approval to M/s Unimag Power Transformer Pvt Ltd, Bengaluru for supply of 500kVA Star 2 rated (EEL-3/5 star) Distribution Transformer.
Ref :	1. Approved by Director (Technical) vide para (11) / 814/18.09.2018 of T.O Note No: GM (QS&S)/DGM-3/BC-11/2018-19/1499 dtd: 13.09.2018. 2. BIS License No: CM/L-6200106381.

Approval is hereby accorded to M/s Unimag Power Transformer Pvt Ltd., 26/A, II phase, Peenya Industrial Area, Bengaluru-560 058 as approved vendor for supply of 500kVA, Star2 rated Distribution Transformer to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self execution works, Turnkey works & Partial Turnkey works etc.,.

Sl. No.	Particulars	Period of validity upto
1.	500kVA star2 rated (EEL-3/5 star), Distribution Transformers, CRGO core, 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	27.07.2023 (Subject to revalidation every year)

The approval is subject to the following conditions:-

1. This O.M is issued only to enlist the firm in vendor list of the BESCOM to manufacture the above star rated Distribution Transformers and BIS the star marking on the product is liable to condition of BIS license.
2. The prospective consumers who purchase above said Distribution transformers shall stand guarantee for the materials for a period of one year from the date of commissioning.
3. The above transformers shall confirm to all tests of the specification as prescribed in the relevant IS/IEC & its amendment from time to time.
4. The above said transformers shall be got inspected by QS&S or the concerned jurisdictional Engineers, BESCOM before they are put into service.
5. BESCOM reserves the right to withdraw the approval issued, in case of any violation of the approved drawing and specification at any time.
6. The loss level shall be maintained as per latest amendments vide gazette notification No: S.O 4062(E) dated: 16.12.2016 by Ministry of Power, GOI in consultation with BIS Shall be obtained.
7. Stainless steel plate of 5" x 2" dimensions with unique ID code shall be welded on the tank of the transformer.
8. For renewal of vendor approval proposal shall be submitted one month prior to expiry of validity of vendor approval.

Approved by Director (Technical)

(Nagarajiah.B.N)
General Manager (El.)
Q, S& S BESCOM.

9/10/18

Copy to-

1. The Chief General Manager (El.) CA / Operations/ Projects, BESCOM, Bangalore.
2. All the Chief Engineer (Electy.,) O&M Zones, BESCOM.
3. The General Managers (Ele.,) Procurement / DAS, BESCOM.
4. All the Superintending Engineers (Ele), CO&M circles, BESCOM.
5. All the Executive Engineers (Ele.) C,O&M Divisions, BESCOM.
6. PS to DT to place before Hon'ble Director (Technical), BESCOM.
7. M/s Unimag Power Transformer Pvt Ltd., 26/A, II phase, Peenya Industrial Area, Bengaluru-560 058 (Ph No:8028396184, E-mail:contact@umpt.in)
8. OC/MF.