



भारतीय मानक ब्यूरो
BUREAU OF INDIAN STANDARDS

Bangalore Branch Office

Address: Peenya Industrial Area, Ist Stage,
Bangalore-Tumkur Road,
Bangalore-560058

Phones : 080-28394955, 28394956

Fax: 080-28398841

E-Mail: bnbo@bis.gov.in

web : http://www.bis.gov.in

REGISTERED A.D

हमारा संदर्भ / Our Ref : BNBO /L- 6200106381

दिनांक / Dated : 11/09/18

विषय / Subject : BIS CERTIFICATION MARKS LICENCE NO. CM/L- 6200106381

✓ M/s UNIMAG POWER TRANSFORMER PVT LTD
NO.26/A, II PHASE,
PEENYA INDUSTRIAL AREA,
BANGALORE
Distt : Bangalore Urban
Karnataka 560058

Dear Sir,

We are forwarding herewith endorsement sheets with respect to the following :

a) **Inclusion of New Varieties**

Kindly acknowledge the receipt.

धन्यवाद / Thanking you,

भवदीय / Yours faithfully,

(RAKESH TANNEERU)
Scientist-C

संलग्न / Encl : As above



भारतीय मानक ब्यूरो

(उपभोक्ता मामले, खाद्य एवं सार्वजनिक वितरण मंत्रालय के अंतर्गत, भारत सरकार)

BUREAU OF INDIAN STANDARDS

(Ministry of Consumer Affairs, Food & Public Distribution, Government Of India)

बेंगलूरु शाखा कार्यालय

BENGALURU BRANCH OFFICE

पीन्या इन्डस्ट्रियल एरिया, पहली स्टेज,
तुमकुर रोड, बेंगलूरु - 560 058

Peenya Industrial Area, 1st Stage,
Tumkur Road, Bengaluru - 560 058.

फोन / Phone : 080- 28394955, 28394956

फैक्स / Fax : +91 080 28398841

ई-मेल / E-mail : bnbo@bis.gov.in

वेबसाइट / Website : www.bis.gov.in

ENDORSEMENT FOR CHANGE (S) IN THE LICENCE

ATTACHMENT TO LICENCE NO. CM/L- 6200106381

| CML/NO | NAME OF THE LICENSEE WITH THE ADDRESS | NAME OF THE PRODUCT | IS NO. |
|------------|--|---|----------------------------|
| 6200106381 | UNIMAG POWER TRANSFORMER PVT LTD NO.26/A, II PHASE, PEENYA INDUSTRIAL AREA BANGALORE Distt : Bangalore Urban Karnataka 560058 | Outdoor type oil immersed distribution transformers | IS 1180 : Part 1 : 2014 |

ENDORSEMENT NO. 1 Dated 11/09/18

The following additional varieties have been included in Columns(2) of the First Schedule and Column (1) of the Second Schedule of the Licence along with the Standard Mark in Column (1) of First Schedule with immediate effect.

Outdoor type oil immersed distribution transformer of rating above 200kVA upto and including 500kVA, Nominal voltage 3.3kV, 6.6kV & 11kV; 3 phase, Non sealed type; Copper wound; CRGO core; Energy Efficiency Level 1, 2 & 3.

Other terms and conditions of Licence remain the same.

(RAKESH TANNEERU)
Scientist - C